



January 15, 2021

RE: Addendum #1 for Hoose Court duplex at 227 S. Scott Street

Attention contractors:

Attached is addendum #1 which contains important information on the bid due date and other construction related items.

Please acknowledge receipt of addendum #1 on your bid form.

Thank you and good luck!

Best,

Pat Lynch
SBH Architect

attached –
227 S. Scott duplex - Addendum #1 dated 1-15-2021

January 15, 2021

Hoose Court – Addendum #1

Please read all addenda items carefully as they may affect the scope and price of your work. If you have questions about items in this addenda or any other documents in the RFP please contact patlynch@sbheritage.org.

1.01 Due date extension:

The bid due date is extended from Wednesday January 27 to **Wednesday, February 10 by 3:00P**. Bidder registration is extended to January 25 for those contractors or vendors who were not sent the RFP directly from SBH.

1.02 Change to exterior sheathing at 1 and 2 hour fire rated wall assemblies:

Sheathing at fire rated walls changed from 5/8" Densglass to 7/16" LP FlameBlock.

Install per drawings and secured per mnfr. specifications.

Sheathing at all other exterior walls is not changed and remains 7/16" OSB.

FRT (Fire Resistant Treated) roof decking remains as and where specified.

1.03 Change at HVAC furnace venting:

Vent at exterior wall changed to PVC concentric vent for combustion and exhaust.

-- End of addendum #1 --